

# ADDENDUM

ADDENDUM NO: 02

PROJECT: Summit Elementary School Addition

PROJECT NO: 19110

DATE: December 18, 2019

BY: Brent Hite



This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

Addendum Pages: ADD1-2 thru ADD2-2

Attached Documents: Sheet AD101 – Revised, Sheet A201 – Revised, Sheet A202 – Revised, Sheet A203 – Revised, Sheet A210 – Revised, Sheet A301 – Revised, Sheet A302 – Revised, Sheet A401 – Revised, Sheet A402 – Revised, Sheet A410 – Revised, Sheet A420 – Revised, Sheet A501 – Revised, Sheet A601 – Revised, Sheet A610 – Revised, Sheet A801 – Revised, Sheet A802 – Revised, Sheet A901 – Revised

## **PART 1 - DRAWINGS**

### **ARCHITECTURAL**

- 1.1 SHEETS AD101, Sheet A201, Sheet A202, Sheet A203, Sheet A210, Sheet A301, Sheet A302, Sheet A401, Sheet A402, Sheet A410, Sheet A420, Sheet A501, Sheet A601, Sheet A610, Sheet A801, Sheet A802, Sheet A901
  - A. The printed scale of the Architectural Series Drawings included in the 100% Construction Documents and Addendum 01 document releases were incorrect. Drawings, where scale is relevant for bidding purposes, are reissued with this addendum and have been verified to print at the correct scale. Architectural Series Drawings, where scale is not relevant for bidding purposes, are not reissued with this addendum.
- 1.2 SHEET A203
  - A. All occurrences of the note regarding roof slope on the roof plan are revised to read "3.5" per 12".
- 1.3 SHEET A302
  - A. Revise Keynote Legend as follows:
    1. Revise Key Note 07 31 13-A to read "ASPHALT SHINGLES (MATCH EXISTING) W/ FELT UNDERLAYMENT".
    2. Revise Key Note 07 31 13-B to read "SELF-ADHERING SHEET UNDERLAYMENT OVER ENTIRE COVERBOARD".
    3. Revise Key Note 07 31 13-C to read "SELF-ADHERING SHEET UNDERLAYMENT PER 07 31 13 PART 3.02".
    4. Revise Key Note 07 31 13-D to read "SELF-ADHERING SHEET UNDERLAYMENT CAP COUNTERFLASHED OVER CURB".

5. Revise Key Note 07 71 00-D to read "MANUFACTURED ROOF EDGE FLASHING"
  6. Add Key Note 07 71 29-A "MANUFACTURED EXPANSION JOINT COPING"
  7. Add Key Note 07 71 29-B "SECONDARY MEMBRANE WATERPROOF SEAL FILLED W/  
INSULATION.
  8. Remove Key Note 08 12 16-A "INTERIOR ALUMINUM DOORS".
  9. Add Key Note 08 41 13-B "WIDE STILE ALUMINUM ENTRANCE DOOR".
- B. Elevation 1/A302, revise Key Note indicating entrance door to read 08 41 13-B
- C. Elevation 2/A302, revise Key Note indicating roof expansion joint cover to read 07 71 29-A
- D. Elevation 3/A302, revise Key Note indicating roof expansion joint cover to read 07 71 29-A

END ADDENDUM